

Spill Summary Report for NRC Report #1161718

Report Date: 9/14/2022

Report Time: 4:05 PM EDT

Region II Hotline Log Entry Information

Data ID: 2040674

Date Of Report: 10/17/2016

NRC #: 1161718

State #:

ERNS #:

Material Type: Oil

Receiver: Jimenez

Material / Amount:

DIELECTRIC FLUID (300 GALLON(S));

Location:

Street:
 City: YONKERS
 County: WESTCHESTER
 State: NY
 Latitude:
 Longitude:

Source of Pollution:

CONSOLIDATED EDISON COMPANY OF NEW YORK

Water Body:

None

State Or EPA Responded:

ConEd and contractor

Initial EPA Action:

Contacted RP, No EPA Response Required

Status:

2 - Closed

URL:

Associated Action Reports

DataID: 0983135

Date: 10/17/2016	Time: 08:47	
Duty Officer/Responder Name: Jimenez	NRC Report #: 1161718	Hotline Log DataID: 2040674
Action Information		
Description: Contact RP, ConEd rep stated that they have detected an oil loss from the oil jacketed distribution line that originates at The Sprain Brook sub station. Con-ed will report to OSC Jimenez when they find the leak.		
Follup-Up:		
Person Contacted		
Name: Chris Muggeo Organization: Consolidated Edison Phone #: 212 580-8383		

NRC Spill Report

NATIONAL RESPONSE CENTER 1-800-424-8802

GOVERNMENT USE ONLYGOVERNMENT USE ONLY***

Information released to a third party shall comply with any
 applicable federal and/or state Freedom of Information and Privacy Laws

Incident Report # 1161718

INCIDENT DESCRIPTION

**** THIS IS A POTENTIAL RELEASE ****

*Report taken by: CIV NYDIA RAWLS at 07:36 on 17-OCT-16

Incident Type: FIXED

Incident Cause: UNKNOWN

Affected Area:

Incident was discovered on 17-OCT-16 at 07:25 local incident time.

Affected Medium: NON-RELEASE (N/A) POTENTIAL RELEASE

REPORTING PARTY

Name: CHRIS MUGGEO

Organization: CONSOLIDATED EDISON COMPANY OF NEW YORK

Address: 31ST ST AND 20TH AVE
 ASTORIA, NY 11105

PRIMARY Phone: (212)5808383

Type of Organization: PUBLIC UTILITY

SUSPECTED RESPONSIBLE PARTY

Name: CHRIS MUGGEO

Organization: CONSOLIDATED EDISON COMPANY OF NEW YORK

Address: 31ST ST AND 20TH AVE
 ASTORIA, NY 11105

PRIMARY Phone: (212)5808383

Type of Organization: PUBLIC UTILITY

INCIDENT LOCATION

TO W. 49TH ST. STATION, MANHATTAN County: WESTCHESTER

City: YONKERS State: NY

FEEDER RUNS FROM THE SPRAIN BROKE STATION IN YONKERS

POTENTIALLY RELEASED MATERIAL(S)

CHRIS Code: OTH Official Material Name: OTHER OIL
Also Known As: DIELECTRIC FLUID
Qty Released: 300 GALLON(S) Qty in Water: 0 UNKNOWN AMOUNT

DESCRIPTION OF INCIDENT

CALLER STATED THAT AN INDICATOR IS REPORTING AN ESTIMATED 4.5 GALLONS PER HOUR RELEASE OF DIELECTRIC FLUID WITH AN ESTIMATED TOTAL LOSS OF 300 GALLONS OF DIELECTRIC FLUID TO AN UNKNOWN SOURCE AT THIS TIME. CALLER STATED CREWS ARE ON SITE INVESTIGATING.

INCIDENT DETAILS

Package: N/A
Building ID:
Type of Fixed Object: OTHER
Power Generating Facility: UNKNOWN
Generating Capacity:
Type of Fuel:
NPDES:
NPDES Compliance: UNKNOWN

IMPACT

Fire Involved: NO Fire Extinguished: UNKNOWN
INJURIES: NO Hospitalized: Empl/Crew: Passenger:
FATALITIES: NO Empl/Crew: Passenger: Occupant:
EVACUATIONS: NO Who Evacuated: Radius/Area:

Damages: NO

		Hours	Direction of
<u>Closure Type</u>	<u>Description of Closure</u>	<u>Closed</u>	<u>Closure</u>
Air:	N		
Road:	N		Major Artery: N
Waterway:	N		
Track:	N		

Passengers Transferred: NO
Environmental Impact: UNKNOWN
Media Interest: UNKNOWN Community Impact due to Material:

REMEDIAL ACTIONS

CREWS ARE ON LOCATION POPPING MANHOLE COVERS AND CHECKING STRUCTURES AT THIS TIME.

Release Secured: NO
Release Rate:
Estimated Release Duration:

WEATHER

ADDITIONAL AGENCIES NOTIFIED

Federal:
State/Local:
State/Local On Scene:
State Agency Number:

NOTIFICATIONS BY NRC

CENTERS FOR DISEASE CONTROL (GRASP)
17-OCT-16 07:44 (770)4887100
DHS INFRSTR SECURITY COMPLIANCE DIV (REGION 2)
17-OCT-16 07:44 (202)4655909
DHS PROTECTIVE SECURITY ADVISOR (PSA DESK)
17-OCT-16 07:44 (703)2355724
DOT CRISIS MANAGEMENT CENTER (MAIN OFFICE)
17-OCT-16 07:44 (202)3661863
U.S. EPA II (MAIN OFFICE)
17-OCT-16 08:26 (732)3214370 MR JIMENEZ
NATIONAL INFRASTRUCTURE COORD CTR (MAIN OFFICE)
17-OCT-16 07:44 (202)2829201
NJ OFC HMLND SECURITY & PREPAREDNES (COMMAND CENTER)
17-OCT-16 07:44 (609)9636817
NJ STATE POLICE (MARINE SERVICES BUREAU)
17-OCT-16 07:44 (609)9636900
NOAA RPTS FOR NY (MAIN OFFICE)
17-OCT-16 07:44 (206)5264911
NATIONAL RESPONSE CENTER HQ (AUTOMATIC REPORTS)

17-OCT-16 07:44 (202)2671136
NEW YORK CITY DEP (BUREAU OF WATER SUPPLY)
17-OCT-16 07:44 (845)3347188
NY STATE DEC SPILL HOTLINE (MAIN OFFICE)
17-OCT-16 07:44 (518)4577362
CTDEP OIL & CHEM SPILL RESP DIV (MAIN OFFICE)
17-OCT-16 07:44 (860)4243338
USCG DISTRICT 1 (COMMAND CENTER)
17-OCT-16 07:44 (617)2238555

ADDITIONAL INFORMATION

*** END INCIDENT REPORT # 1161718 ***
Report any problems by calling 1-800-424-8802
PLEASE VISIT OUR WEB SITE AT <http://www.nrc.uscg.mil>